


NOTES:

1. DETAIL IS DESIGNED TO ACCOMMODATE 50% (MAX.) TOTAL MOVEMENT.
2. BACKER ROD AND TOOLED SEALANT OR OTHER MANUFACTURER APPROVED WATERTIGHT EXPANSION JOINT SYSTEM ARE REQUIRED TO BE INSTALLED PRIOR TO PRIMETAK INSTALLATION.

G:\My Drive\Epro Master Folder\Drafting\Details\Walls\Primetak\55.252.6. WALL CRACK AND JOINT TREATMENT - PLAN VIEW - EXPANSION JOINT - CORNER.dwg [Detail] April 27, 2021 - 8:19am

WALL CRACK AND JOINT TREATMENT - NON-HYDROSTATIC - PLAN VIEW - EXPANSION JOINT - CORNER

	SYSTEM NAME	DRAWING NUMBER	<h1>PRIMETAK</h1>
	PRIMETAK	55.252.6	
	DRAFTER	DATE	
	RJT	4/05/2021	

AS A SUPPLIER OF FINISHED PRODUCTS ONLY, EPRO SERVICES, INC. DOES NOT ASSUME RESPONSIBILITY FOR ERRORS IN DESIGN, ENGINEERING OR DIMENSIONS. THE PROJECT TEAM MUST VERIFY ALL DIMENSIONS AND SUITABILITY OF DETAILS. THE PRODUCTS LISTED ARE TRADEMARKS OF EPRO SERVICES, INC.

NTS

PAGE 1 OF 1